


5.3 Detector Signal Output

The built-in and separate detector signals are output as follows.


- (1) For S series and L series
Incremental, absolute, and high resolution pulse coder
Separate type incremental, absolute pulse coder unit

Signal names of the pulse coder	Pin names of the connector		
	Incremental MS310A20-29PW (Separate) (MS3102A2029P)	Absolute MS3102A22-14P (Separate) (MS3102A22-14P)	High-resolution MS3102A22-14P (NOT AVAILABLE SEPARATE)
A *A	A (A) D (D)	A (A) B (B)	A B
B *B	B (B) E (E)	C (C) D (D)	C D
Z *Z	F (F) G (G)	E (E) F (F)	E F
C1 C2 C4 C8	C (-) P (-) L (-) M (-)	G (G) H (H) J (J) K (K)	G H J K
+5V 0V Shield OH1 OH2 REQ +6VA 0VA	J, K (CJK) N, T (NPT) H (H) R (-) S (-) - - - - - -	L (L) M (M) N (N) P (-) R (-) S (S) T (T) U (U)	L, T M, U N P R - - -

MS3102A20-29P



MS3102A20-29PW



MS3102A22-14P

